

Form No. GWS-25

OFFICE OF THE STATE ENGINEER  
COLORADO DIVISION OF WATER RESOURCES  
818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203  
(303) 866-3581

889

WELL PERMIT NUMBER

44188-F-R

DIV. 1

WD 5

DES. BASIN

MD

APPLICANT

LAZY H GUEST RANCH  
BOX 248  
ALLENSPARK, CO 80510-

(303) 747-2532

APPROVED WELL LOCATION

BOULDER COUNTY

NW 1/4 SE 1/4 Section 25

Township 3 N Range 73 W Sixth P.M.

DISTANCES FROM SECTION LINES

2200 Ft. from South Section Line

2350 Ft. from East Section Line

PERMIT TO CONSTRUCT A WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-90-137(2) for the replacement of an existing well, permit no. 44188-F (decreed by the Division 1 Water Court as Lazy H Guest Ranch Well, case no. W-8626). The old well must be plugged and abandoned in accordance with Rule 15 of the Water Well Construction Rules. A Well Abandonment Report form must be submitted within sixty (60) days after construction of the new well, affirming that the old well was plugged and abandoned.
- 4) Approval of this replacement permit shall not result in an expanded use of ground water. The use of ground water from this well limited to commercial uses for a dude ranch.
- 5) The maximum pumping rate of this well shall not exceed 15 GPM.
- 6) The average annual amount of ground water to be appropriated shall not exceed 5 acre-feet.
- 7) The owner shall mark the well in a conspicuous place with well permit number(s), name of the aquifer, and court case number(s) as appropriate. The owner shall take necessary means and precautions to preserve these markings.
- 8) This well shall not be pumped unless included in a court approved plan for augmentation or a substitute water supply plan approved by the State Engineer.
- 9) A totalizing flow meter must be installed on this well and maintained in good working order. Permanent records of all diversions must be maintained by the well owner (recorded at least annually) and submitted to the Division Engineer upon request.
- 10) This well shall be constructed at least 600 feet from any existing well completed in the same aquifer that is not owned by the applicant.
- 11) Replacement of this well to a location more than 200 feet from the original decreed location is a change in water right. The decree must also be changed to reflect use of the water for uses other than drinking and sanitary purposes (ie. animal watering, lawn and garden irrigation & the swimming pool). This well shall be junior to all vested water rights until such time as the changes have been approved by the Division 1 Water Court. The well then must be operated in accordance with the terms and conditions of that decree.
- 12) This well is subject to administration by the Division Engineer in accordance with applicable decrees, statutes, rules, and regulations.

LAN  
2-2-99

OWNER'S COPY

APPROVED  
RAN

*[Signature]*  
State Engineer

*[Signature]*

By

DEC 07 2000

FORM NO. GMS-31 11/90	<b>WELL CONSTRUCTION AND TEST REPORT</b> STATE OF COLORADO, OFFICE OF THE STATE ENGINEER		For Office Use only																										
1.	WELL PERMIT NUMBER <u>44188 -F-R</u>																												
2.	OWNER NAME(S) <u>PHIL OLBERT LAZY H GUEST RANCH</u> Mailing Address <u>BOX 248</u> City, St. Zip <u>ALLENSPARK, CO 80510</u> Phone ( <u>303</u> ) <u>7474-2532</u>																												
3.	WELL LOCATION AS DRILLED: <u>NW 1/4 SE 1/4, Sec. 25 Twp. 3 N</u> , Range <u>73W 6th</u> DISTANCES FROM SEC. LINES: <u>2300</u> ft. from <u>SOUTH</u> Sec. line. and <u>2400</u> ft. from <u>EAST</u> Sec. line. OR <small>(north or south) (east or west)</small> SUBDIVISION: _____ LOT _____ BLOCK _____ FILING(UNIT) _____ STREET ADDRESS AT WELL LOCATION: _____																												
4.	GROUND SURFACE ELEVATION _____ ft. DRILLING METHOD <u>AIR PERCUSSION</u> DATE COMPLETED <u>JAN 5 2000</u> TOTAL DEPTH <u>500</u> ft. DEPTH COMPLETED <u>500</u> ft.																												
5.	<b>GEOLOGIC LOG:</b> <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:10%;">Depth</th> <th>Description of Material (Type, Size, Color, Water Location)</th> </tr> </thead> <tbody> <tr><td>0-3</td><td>TOP SOIL</td></tr> <tr><td>3-45</td><td>BROWN GRANITE</td></tr> <tr><td>45-110</td><td>GRAY GRANITE</td></tr> <tr><td>110-160</td><td>RED GRANITE 120</td></tr> <tr><td>160-300</td><td>GRAY GRANITE</td></tr> <tr><td>300-315</td><td>White Quartz</td></tr> <tr><td>315-400</td><td>GRAY GRANITE</td></tr> <tr><td>400-420</td><td>WHITE QUARTZ</td></tr> <tr><td>420-500</td><td>GRAY GRANITE 425</td></tr> </tbody> </table>		Depth	Description of Material (Type, Size, Color, Water Location)	0-3	TOP SOIL	3-45	BROWN GRANITE	45-110	GRAY GRANITE	110-160	RED GRANITE 120	160-300	GRAY GRANITE	300-315	White Quartz	315-400	GRAY GRANITE	400-420	WHITE QUARTZ	420-500	GRAY GRANITE 425	<b>6. HOLE DIAM. (in.)</b> <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:10%;">From (ft)</th> <th>To (ft)</th> </tr> </thead> <tbody> <tr><td>0</td><td>20</td></tr> <tr><td>20</td><td>500</td></tr> </tbody> </table>	From (ft)	To (ft)	0	20	20	500
Depth	Description of Material (Type, Size, Color, Water Location)																												
0-3	TOP SOIL																												
3-45	BROWN GRANITE																												
45-110	GRAY GRANITE																												
110-160	RED GRANITE 120																												
160-300	GRAY GRANITE																												
300-315	White Quartz																												
315-400	GRAY GRANITE																												
400-420	WHITE QUARTZ																												
420-500	GRAY GRANITE 425																												
From (ft)	To (ft)																												
0	20																												
20	500																												
	<b>7. PLAIN CASING</b> <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:10%;">OD (in)</th> <th style="width:10%;">Kind</th> <th style="width:10%;">Wall Size</th> <th style="width:10%;">From(ft)</th> <th style="width:10%;">To(ft)</th> </tr> </thead> <tbody> <tr><td>7.0</td><td>STEEL</td><td>.188</td><td>+1</td><td>20</td></tr> <tr><td>4"</td><td>PVC</td><td>.237</td><td>10</td><td>380</td></tr> </tbody> </table>		OD (in)	Kind	Wall Size	From(ft)	To(ft)	7.0	STEEL	.188	+1	20	4"	PVC	.237	10	380												
OD (in)	Kind	Wall Size	From(ft)	To(ft)																									
7.0	STEEL	.188	+1	20																									
4"	PVC	.237	10	380																									
	<b>PERF. CASING: Screen Slot Size:</b> <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:10%;">Screen Slot Size</th> <th style="width:10%;">From(ft)</th> <th style="width:10%;">To(ft)</th> </tr> </thead> <tbody> <tr><td>.028</td><td>10</td><td>380</td></tr> <tr><td>.028</td><td>380</td><td>500</td></tr> </tbody> </table>		Screen Slot Size	From(ft)	To(ft)	.028	10	380	.028	380	500																		
Screen Slot Size	From(ft)	To(ft)																											
.028	10	380																											
.028	380	500																											
	<b>8. FILTER PACK:</b> Material _____ Size _____ Interval _____	<b>9. PACKER PLACEMENT:</b> Type _____ Depth _____																											
	<b>10. GROUTING RECORD:</b> <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:10%;">Material</th> <th style="width:10%;">Amount</th> <th style="width:10%;">Density</th> <th style="width:10%;">Interval</th> <th style="width:10%;">Placement</th> </tr> </thead> <tbody> <tr><td>CEMENT</td><td>30 GAL</td><td>15 LBS</td><td>3-20</td><td>POURED</td></tr> </tbody> </table>		Material	Amount	Density	Interval	Placement	CEMENT	30 GAL	15 LBS	3-20	POURED																	
Material	Amount	Density	Interval	Placement																									
CEMENT	30 GAL	15 LBS	3-20	POURED																									
	REMARKS: _____																												
11.	DISINFECTION: Type <u>HTH</u> Amt. Used <u>10 GAL.</u>																												
12.	<b>WELL TEST DATA:</b> <input type="checkbox"/> Check box if Test Data is submitted on Supplemental Form. TESTING METHOD <u>BLOW TEST</u> Static Level <u>15</u> ft. Date/Time measured <u>1-5-00 10:00AM</u> , Production Rate <u>15</u> gpm. Pumping level <u>500</u> ft. Date/Time measured <u>1-5-00 5:00 PM</u> , Test length (hrs.) <u>ONE</u> Remarks _____																												
13.	I have read the statements made herein and know the contents thereof, and that they are true to my knowledge. [Pursuant to Section 24-4-104 (13)(a) C.R.S., the making of false statements herein constitutes perjury in the second degree and is punishable as a class 1 misdemeanor.] CONTRACTOR <u>HERSH &amp; SON WELL DRILLING, INC.</u> Phone <u>(970) 667-4096</u> Lic. No. <u>889</u> Mailing Address <u>9205 W. CTY. RD. 38 E LOVELAND, CO 80538</u>																												
	Name/Title (Please type or print) <b>LARRY HERSH (PRESIDENT)</b>	Signature <i>Larry Hersh</i>	Date <u>1-21-2000</u>																										